



Attestation of Conformity

ISO/IEC, EN & TIA/EIA Screened Class E_A / Category 6A Two Connector Channel

**Telegärtner Karl Gärtner GmbH
Lerchenstrasse 35
D-71144 Steinenbronn, Germany**

Attestation of Conformity No. 107522

This type of Class E_A / Category 6A screened two connector channel has been tested by 3P Third Party Testing and complies with the Class E_A channel requirements of Amendment 1 to 2nd Edition ISO/IEC 11801 (draft N 1255) and Amendment 1 to CENELEC prEN 50173-1 (draft Sec0201), the Category 6A channel requirements of TIA/EIA-568-B.2-10 (draft 5.0) and 10 Gigabit Ethernet requirements of IEEE P802.3an. The Attestation of Conformity is only valid for the actually tested channel samples in T568B designation and consisting of the following Telegärtner components:

<i>Cables:</i>	<i>Horizontal Cables,</i>	<i>P/N L02002A0120-AMJ 900 S/FTP 4x2xAWG23/1 LSFZRH</i>
	<i>Flexible Cable from Patch Cord,</i>	<i>P/N L02002A0121-AMJ 900 S/FTP 2x(4x2xAWG23/1) LSFZRH</i>
	<i>Qualification Status:</i>	<i>P/N L00003A0055-patchcord S/FTP Cat.7 LSZH 5,0m Manufacturer Verified</i>
<i>Conn. Hardw.:</i>	<i>Keystone Jacks,</i>	<i>P/N J00029K0036 and P/N J00029L0036-AMJ module K Cat.6+</i>
	<i>Qualification Status:</i>	<i>having PCB Marking 024 Manufacturer Verified</i>
<i>Patch Cord:</i>	<i>5,0 m,</i>	<i>P/N L00003A0055-patchcord S/FTP Cat.7 LSZH 5,0m</i>
	<i>Qualification Status:</i>	<i>Manufacturer Verified</i>

Hoersholm, 3 January 2007

Ole Lambertsen

Ole Lambertsen
Test Responsible

Hoersholm, 3 January 2007

Poul Villien

Poul Villien
Coordinating Manager