

Certificate



Aktiengesellschaft

No. z2536a-11-E

Customer:

Telegärtner Karl Gärtner GmbH
Lerchenstr. 35
D-71144 Steinenbronn

Test sample(s):

- Connector:
Telegärtner AMJ-S Module Cat.6_A T568A/B
Part-No.: J00029A2000; J00029A2001; J00029A2110; J00029A2111
J02023A0039; J02023A0040; J02023A0205; J02023A0206

Applied standard(s):

- ISO/IEC 11801 AMD2 (2010-04)
- IEC 60603-7-51 - Ed. 1.0 (2010-03)

Results:

Up to a bandwidth of **500 MHz** the sample meet the **Category 6_A** limits of the specified standards and regulations.

Connector, Category 6_A

The test results which were determined in the course of the measurement refer to the submitted specimen. Any future technical modifications of the verified products are subject to the responsibility of the manufacturer.

This Certificate refers to the comprehensive test report, no. **P2536a-11-E**, from **March 28th, 2011** and shall only be applicable in conjunction with the test report.

Bexbach, March 28th, 2011

Dirk Wilhelm, engineer
(Chairman of the Managing Board)



GHMT AG
In der Kolling 13
D-66450 Bexbach
Phone: +49 (0) 68 26 / 92 28 – 0
Fax: +49 (0) 68 26 / 92 28 – 99
Email: info@ghmt.de