

# PREMIUM Certificate



Aktiengesellschaft

No. z2449b-10-E

## Customer:

Telegärtner Karl Gärtner GmbH  
Lerchenstr. 35  
D-71144 Steinenbronn

## Test sample(s):

- Connector:  
**Telegärtner AMJ-Module K Cat.6<sub>A</sub> T568A/B**  
Part No.: J00029K0036; J00029L0036  
J00029A0077; J00029B0077

## Applied standard(s):

- ISO/IEC 11801 AMD2 (2010-04)
- IEC 60603-7-51 - Ed. 1.0 (2010-03)

## Results:

Up to a bandwidth of **500 MHz** the sample meet the **Category 6<sub>A</sub>** limits of the specified standards and regulations.

## Connector, Category 6<sub>A</sub>, GHMT PVP

This certificate, based on participation in the **GHMT PREMIUM Verification Program (GHMT PVP)**, authorizes to apply the GHMT PREMIUM marking. Ongoing compliance with the specifications is monitored within the framework of regular sampling, which cannot be influenced by the customer, thus defining high standards as regards continuous manufacturing quality.

This Certificate refers to the comprehensive test report, **no. P2449b-10-E, from May 30<sup>th</sup>, 2011** and shall only be applicable in conjunction with the test report.

Bexbach, May 30<sup>th</sup>, 2011

Dirk Wilhelm, engineer  
(Chairman of the Managing Board)



GHMT AG  
In der Kolling 13  
D-66450 Bexbach  
Phone: +49 (0) 68 26 / 92 28 – 0  
Fax: +49 (0) 68 26 / 92 28 – 99  
Email: info@ghmt.de

valid until: November 30<sup>th</sup> 2011